

NOTICE TO BIDDERS

Fairview Public Schools
2008 Parking Lot Improvements

Addendum 01: Friday, July 11, 2008 8:00am

Please note the following changes to the specifications

Page 31

SECTION 21 CONCRETE CURBING AND SIDEWALK

PART 2 PRODUCTS

2.01 Materials

- B. The fine aggregate shall meet the requirements of Michigan Department of Transportation Specification for **Class II sand**.

Page 46

The Pole for the light should be rated for 90MPH. The correct catalog number is PFT14023M259

Please note the following changes to the approximate quantities shown on the cover sheet and page 9 of the specifications:

4" Concrete sidewalk	3275 SQFT
Pulverize Bit	4469 SQYD

The bituminous may be completely removed instead of pulverized. The aggregate base is still required to be a minimum of 6". The contractor would be responsible for disposing of the removed bituminous.